

2010 Consumer Confidence Report

Water System Name: Esparto Community Services District Report Date: March 25, 2011

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2010.

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.

Type of water source(s) in use: (4) Four Deep Wells

Name & location of source(s): Well # 1A (Adjacent To Fire Station); Well # 4 (Omega St.); Well # 5 (ECSD Office); Well # 6 (Campos Dr.); All Wells are located within the District Service Area.

Drinking Water Source Assessment information: Assessment was completed April 2003, with no contaminates. If you would like a copy please e-mail us at GM@ecsd-ca.org or visit our office and request copy.

Time and place of regularly scheduled board meetings for public participation: Board meetings are held the second Wednesday of every month, at 7:00 pm in the ECSD Board/Control Room at 26490 Woodland Ave. Esparto, Ca.

For more information, contact: Jason Findley, Utility Systems Operator Phone: (530) 787-4502

TERMS USED IN THIS REPORT

<p>Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.</p> <p>Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).</p> <p>Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.</p> <p>Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.</p> <p>Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.</p>	<p>Primary Drinking Water Standards (PDWS): MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.</p> <p>Secondary Drinking Water Standards (SDWS): MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.</p> <p>Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.</p> <p>Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.</p> <p>Variances and Exemptions: Department permission to exceed an MCL or not comply with a treatment technique under certain conditions.</p> <p>ND: not detectable at testing limit</p> <p>ppm: parts per million or milligrams per liter (mg/L)</p> <p>ppb: parts per billion or micrograms per liter (ug/L)</p> <p>ppt: parts per trillion or nanograms per liter (ng/L)</p> <p>ppq: parts per quadrillion or picogram per liter (pg/L)</p> <p>pCi/L: picocuries per liter (a measure of radiation)</p>
--	--

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants* that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the USEPA and the state Department of Public Health (Department) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. Department regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

Tables 1, 2, 3, 4, 5, 7, and 8 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The Department allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

TABLE 1 – SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA

Microbiological Contaminants (complete if bacteria detected)	Highest No. of Detections	No. of months in violation	MCL	MCLG	Typical Source of Bacteria
Total Coliform Bacteria	(In a mo.) 0	0	More than 1 sample in a month with a detection	0	Naturally present in the environment
Fecal Coliform or <i>E. coli</i>	(In the year) 0	0	A routine sample and a repeat sample detect total coliform and either sample also detects fecal coliform or <i>E. coli</i>	0	Human and animal fecal waste

TABLE 2 – SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER

Lead and Copper (complete if lead or copper detected in the last sample set)	No. of samples collected	99 th percentile level detected	No. sites exceeding AL	AL	PHG	Typical Source of Contaminant
Lead (ppb)	22	0.0025	0	15	2	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits
Copper (ppm)	22	.64	0	1.3	0.17	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

TABLE 3 – SAMPLING RESULTS FOR SODIUM AND HARDNESS

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Sodium (ppm)	7/30/08	39.5	33-45	none	none	Salt present in the water and is generally naturally occurring
Hardness (ppm)	7/30/08	260	230-400	none	none	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

*Any violation of an MCL or AL is asterisked. Additional information regarding the violation is provided later in this report.

TABLE 4 – DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
GROSS ALPHA ACTIVITY (pCi/l)	7/30/08	ND	1.80-3.96	15	N/A	Erosion of Natural Deposits
BARIUM	7/30/08	.19	.12-.27	1	(2) 1	Discharge of oil drilling wastes, metal refineries of erosion of natural deposits
CHROMIUM (ppb)	7/30/08	7	ND-16	50	(100) N/A	Discharge from steel of pulp mills; Erosion of natural deposits
FLORIDE (ppm)	7/30/08	.46	.40-.51	2	(NA) 1	Erosion of natural deposits, water additive that promotes strong-teeth; discharge from fertilizer and aluminum factories
Nitrate (ppm)	7/30/08	6.4	3.9-18.0	45	(N/A) 45	Runoff and leaching from fertilizer use; Leaching from septic tank; sewage; erosion of natural deposits

TABLE 5 – DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
COLOR (units)	7/30/08	2.5	<1.0-10	15	(N/A) N/A	Natural occurring organic materials.
IRON (ppm)	7/30/08	625*	ND-2500	300	(N/A) N/A	Leaching from natural deposits; Industrial wastes
MANGANESE (ppm)	7/30/08	20	ND-80	50	(N/A) N/A	Leaching from natural deposits
ODOR (units)	7/30/08	ND	ND	3	(N/A) N/A	Natural occurring organic materials.
TURBIDITY (NTU)	7/30/08	3.41	.12-13	5	(N/A) N/A	Soil runoff
TOTAL DISSOLVED SOLIDS [TDS] (ppm)	7/30/08	365	310-460	1000	(N/A) N/A	Runoff / Leaching from natural deposits
SPECIFIC CONDUCTANCE (micro/ohms)	7/30/08	657.5	560-830	1600	(N/A) N/A	Substances that form ions when in water, seawater influence
CHLORIDE	7/30/08	31.25	15-51	500	(N/A) N/A	Runoff / Leaching from natural deposits
SULFATE (ppm)	7/30/08	25.25	24-29	500	(N/A) N/A	Runoff / Leaching from natural deposits; Industrial wastes

TABLE 6 – DETECTION OF UNREGULATED CONTAMINANTS

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	Notification Level	Health Effects Language
CHROMIUM- HEXAVALENT	6/13/06 One time sample	ND		0.05	N/A
PERCHLORATE	7/30/08 One time sample	ND		6.0	N/A

*Any measurement exceeding an MCL, MRDL, or TT is asterisked. Additional information regarding the measurement is provided later in this report.

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA’s Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

The Esparto CSD is dedicated and committed to providing our customers with the highest quality drinking water available. We are pleased to announce that the Esparto CSD water supply meets or exceeds all federal and state standards. Our goal is to continue to provide a safe and dependable supply of drinking water.

Under the guidelines provided by the U.S. Environmental Protection Agency and the California Department of Public Health, Esparto CSD monitors and tests the drinking water from source to tap. This ensures that your water meets all regulatory requirements for health standards.

Summary Information for Samples Exceeding a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement

SAMPLE EXCEEDING A MCL, MRDL, AL, TT, OR MONITORING AND REPORTING REQUIREMENT				
Chemical / Constituent	Explanation	Duration	Actions Taken to Correct the Violation	Health Effects Language
Iron	Secondary MCL	Single Sample	N/A, Secondary MCL Guideline	None

For Water Systems Providing Ground Water as a Source of Drinking Water

**TABLE 7 – SAMPLING RESULTS SHOWING
FECAL INDICATOR-POSITIVE GROUND WATER SOURCE SAMPLES**

Microbiological Contaminants (complete if fecal-indicator detected)	Total No. of Detections	Sample Dates	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
<i>E. coli</i> N/A	(In the year)		0	(0)	Human and animal fecal waste
Enterococci	(In the year)		TT	n/a	Human and animal fecal waste
Coliphage	(In the year)		TT	n/a	Human and animal fecal waste

**Summary Information for Fecal Indicator-Positive Ground Water Source Samples,
Uncorrected Significant Deficiencies, or Ground Water TT**

SPECIAL NOTICE OF FECAL INDICATOR-POSITIVE GROUND WATER SOURCE SAMPLE

N/A

SPECIAL NOTICE FOR UNCORRECTED SIGNIFICANT DEFICIENCIES

N/A

VIOLATION OF GROUND WATER TT

TT Violation	Explanation	Duration	Actions Taken to Correct the Violation	Health Effects Language
N/A				

For Systems Providing Surface Water as a Source of Drinking Water

TABLE 8 - SAMPLING RESULTS SHOWING TREATMENT OF SURFACE WATER SOURCES	
Treatment Technique ^(a) (Type of approved filtration technology used)	N/A
Turbidity Performance Standards ^(b) (that must be met through the water treatment process)	Turbidity of the filtered water must: 1 - Be less than or equal to ____ NTU in 95% of measurements in a month. 2 - Not exceed ____ NTU for more than eight consecutive hours. 3 - Not exceed ____ NTU at any time.
Lowest monthly percentage of samples that met Turbidity Performance Standard No. 1.	
Highest single turbidity measurement during the year	
Number of violations of any surface water treatment requirements	

(a) A required process intended to reduce the level of a contaminant in drinking water.

(b) Turbidity (measured in NTU) is a measurement of the cloudiness of water and is a good indicator of water quality and filtration performance. Turbidity results which meet performance standards are considered to be in compliance with filtration requirements.


*Any violation of a TT is marked with an asterisk. Additional information regarding the violation is provided below.

Summary Information for Violation of a Surface Water TT

VIOLATION OF A SURFACE WATER TT				
TT Violation	Explanation	Duration	Actions Taken to Correct the Violation	Health Effects Language
N/A				

Summary Information for Operating Under a Variance or Exemption

N/A



For additional information, please contact the District office at:

Esparto Community Services District
 P.O. Box 349
 26490 Woodland Ave
 Esparto, CA 95627

Telephone: 530-787-4502
 Fax: 530-787-4219
 E-mail: GM@ecsd-ca.org